

GLOUCESTER TOWNSHIP FIRE DISTRICT #5
BUREAU OF FIRE PREVENTION
1781 Sicklerville Road
Sicklerville, NJ 08081
856-228-0678 ♦ Fax: 856-374-0424
www.glotwpfiredistrict5.com

Effective 4/4/2022

**2022 SMOKE DETECTOR, CARBON MONOXIDE DETECTOR AND FIRE EXTINGUISHER
CERTIFICATION APPLICATION**

APPLICATIONS MUST BE PRESENTED IN PERSON TO GTFD#5. MAIL IN APPLICATIONS NO LONGER ACCEPTED.

Owner Information:

Owner Name: _____

Property Address: _____

Phone: _____

Block: _____ Lot: _____

Property Status: [] Occupied [] Vacant

Realtor Information:

Name: _____

Company: _____

Address: _____

Phone: _____

Settlement Date: _____

GTFD5 - Administrative Use Only

Electricity On: YES _____ NO _____

Regular Temporary

Inspection Date: _____ 9am-11am

Inspected By: _____

Pass Fail

1. _____

2. _____

3. _____

4. _____

Re-inspection Date: _____ 9am-11am

Inspected By: _____

Pass Fail

1. _____

2. _____

3. _____

4. _____

INSPECTION CHECKLIST

House Address Numbers

House Address Numbers are numerical characters, contrasting color from the house, at least 4" high, permanently affixed to the house & visible from the street. Light post or mailbox numbers are NOT acceptable.

Smoke Alarms

- Smoke alarm located on every level of dwelling
- Basement level alarm is located at bottom of stairwell, at ceiling level (not between joists).
- Bedroom hallway alarms MUST be within 10 feet of ALL bedroom doors.
- Electric smoke alarms (hardwired) **CAN NOT** be replaced with battery operated alarms.
- Do **NOT** install smoke alarms in kitchen, bathrooms, near forced air ducts or furnaces, in the "dead air" space where the ceiling meets the wall, close to ceiling fans, in crawl spaces or attics.
- Battery operated smoke detectors **must** be powered with 10 year lithium batteries.
Battery smoke detectors cannot replace hardwired smoke alarms.
- **Smoke Alarms MUST be less than 10 years old and operational.**

Carbon Monoxide Alarms

- Located in the hallway, within 10 feet of **ALL** bedrooms doors.
- Installed per manufacturer's instructions.
- Carbon monoxide alarm(s) are less than 7 years old and are operational.
- Do NOT place alarms in electrical outlets that can be turned off by a switch or that are located against floor molding. Plug-in, battery powered and hardwired CO alarms are acceptable.

Fire Extinguisher

- ABC type, rated for residential use.
- No smaller than a 2A-10B:C (10 lbs).
- Must be dated or tagged for current year by a certified Division of Fire Safety contractor or have the receipt of a recently purchased extinguisher.
- Must be MOUNTED within 10 feet of the kitchen (on bracket provided by manufacturer) and located in the path of egress.
- **Readily accessible and not obstructed from view.**

Smoke Alarms

Inspection date scheduled 10 or more days prior to settlement.	\$35.00
Inspection date scheduled 4-9 days prior to settlement.	\$70.00
Inspection date scheduled less than 4 days prior to settlement.	\$125.00

Payment in Cash, Check, or Money Order. Check made payable to GTFD5.

GTFD5-ADMINISTRATIVE USE ONLY

Inspection Date: _____ (9am-11am) Property Address: _____

Payment: Cash Check # _____ Money Order Amount Received: _____

Fee received by: _____ Fee received from: _____